



ADDENDUM NUMBER ONE

January 27, 2012

To all contract bidders of record for the work titled:

**Idaho Transportation Department
District 2 - Kooskia Equipment Storage Building
Requisition #: K072290**

Please notify everyone concerned (subcontractors and suppliers) as to the issuance and contents of this Addendum prior to the date of bid opening. The following changes, deletions and/or additions have been made to the above mentioned project. All other information will remain the same. **This page must be signed and returned with your bid documents.** This Addendum is a part of the contract documents and modifies them as follows:

GENERAL

The following have been approved for use on this project, provided compliance with the remainder of the specifications is adhered to:

Pre-Engineered Metal Building Manufacturer

Nucor Building Systems

Propane Unit Heaters

Lennox

Hollow Metal Doors

Mesker HM

Modine

Reznor

Exhaust Fans

Greenheck

Louvers

Greenheck

QUESTIONS AND ANSWERS

Q1 – The detail 3/3 on sht. #3 shows the bottom of the grade beam at the bottom of the footings. The elevations on sheet #5 indicate the bottom of the grade beam at the top of the footings. *At what elevation does the bottom of the grade beam need to be at?*

A1 – The bottom of the grade beam is at the bottom of the footing as shown in detail 3/3 on sheet 3.

End of Addendum One

This page MUST BE SIGNED, DATED AND RETURNED with your BID DOCUMENTS

Signature: _____ Date: _____

I acknowledge receipt of this Addendum and its contents.
